


PLAN VIEW



ELEVATION

NOTES:

1. BY-PASS MAY BE INSIDE METER BOX OR OUTSIDE METER BOX. IF INSTALLED OUTSIDE METER BOX A CASING AND COVER WILL BE REQUIRED OVER BY-PASS VALVE.
2. 1-1/2 INCH AND 2 INCH BY-PASS VALVES MUST BE BALL VALVES. THREE INCH AND LARGER TO BE RESILIENT SEATING SHUT-OFF VALVES.
3. METERS DEEPER THAN 30 INCHES TO TOP OF PIPE MUST BE RAISED TO 30 INCHES.
4. INLET AND OUTLET VALVES TO BE INSTALLED AT EACH END OF METER.

MINIMUM  
VAULT SIZE

	A	B	C
4" & 6"	60"	100"	42"
8" & 10"	80"	132"	42"